



**SPRAY BOOTH CORRECTION LIST (2013 California Codes)**

<b>Plan Check No:</b>	<b>Review No:</b>	<b>Plan Check Expiration Date: 1 year from submittal</b>
Site Address:		
Project Description:		Area square feet:
Type of Occupancy:		Wind Speed: $V_{ult} = 110$ mph , exposure C
Type of Construction:		Fire Sprinklered:
Applicant:		Phone:
Owner:		Phone:
Architect/Engineer/Contractor:		Phone:
Reviewed by:	Date:	Ph: (909) - , e-mail:

**INSTRUCTIONS:**

- ⇒ Numbers in brackets refer to code sections of 2013 California Building Code [CBC], 2013 California Fire Code [CFC], 2013 California Mechanical Code [CMC], and 2013 California Electrical Code [CEC].
- ⇒ Correct original drawings. Reprint and submit 2 new sets together with the “marked-up” set. Return this corrections list with corrected plans.
- ⇒ In the Respond column, please indicate the sheet number and detail or note number on the plan where the corrections are made.
- ⇒ Itemize any changes, revisions, or additions made to drawings that are not a direct answer to a correction on a separate sheet.
- ⇒ Additional plan check fee will be required after third review on hourly rate basis.

Item #	Sheet #	Correction Requested	Respond
		<b>A. APPROVALS:</b>	
1		Obtain approval from the following departments: -Planning Department -Fire Department -SCAQMD	
2		Fill out & <u>print on plan</u> the attached “Hazardous Material Disclosure Form” and “SCAQMD’s Air Quality Permit Check List”.	
		<b>B. SUBMITTAL REQUIREMENTS:</b>	
3		Provide the following on the title page of drawings: a) Job site address. b) Owner name and address. c) Designer name and address with wet signature. d) Building type of construction & occupancy classification. e) Indicate if building is fire sprinklered or not.	

		f) Building area & tenant space area square footage.	
4		Provide a vicinity map.	
5		Provide site plan showing: a) Buildings & tenant space location, property lines, and building setbacks. b) Exhaust duct outlet distance to property lines & to adjacent buildings c) Use of all adjacent tenant suites or spaces.	
6		Provide overall building floor plan showing: a) The proposed & any existing spray booths location and sizes. b) Use of all rooms or areas. c) Fully dimensioned floor plan. d) Show all exit doors.	
7		Provide 2 complete final sets of plans, wet stamped & signed by a registered professional designer.	
8		Show the correct address of building on plans. [CBC105.3 ]	
9		Provide an index of drawings on the cover sheet of plans.	
10		Provide legends and abbreviations that are shown throughout the plans. [CBC 105.3]	
11		Void or delete all plans, details, and notes that do not pertain to this project.	
12		Indicate on plan the applicable current codes: -2013 CBC / 2012 IBC -2013 CFC / 2012 IFC -2013 CMC / 2012 UMC -2013 CEC / 2011 NEC	
13		If the spray booth is installed in a building that has not been approved for the proposed type of occupancy (change of occupancy), submit a complete plan prepared by a registered design professional for the proposed change of occupancy to include code analysis (such as allowable area analysis, type of construction, sprinkler requirements, number of plumbing fixtures, fire rating of walls, fire separation distance, occupancy separation, etc...)	
14		If the existing or proposed building occupancy is an auto repair garages: a) Specify on plan if there is any open flame or welding area. b) Repair garages with grease racks or grease pits shall be provided with an oil or flammable liquid interceptor that connected to all necessary floor drains per CPC 1017.1.	
<b>C. EXTERIOR SPRAY BOOTH BUILDING:</b>			
15		Indicate on plan the following note: - Wind Speed: $V_{ult} = 110$ mph , exposure C	
16		Submit structural plan & calculation (gravity & lateral analysis) for exterior spray booths prepared by a registered professional designer.	
17		For exterior spray booth show the general site drainage slope and direction.	
18		The ground immediately adjacent to the foundations shall be sloped away from the building at a slope of not less than one unit vertical in 20 units horizontal (5%-slope) for a minimum distance of 10' measured perpendicular to the face of the wall. If physical obstructions or lot lines prohibit 10' of horizontal distance, a 5% slope shall be provided to an approved alternative method of diverting water away from the foundation. Swales used for this	

		purpose shall be sloped a minimum of 2% where located within 10' of the building foundation. Impervious surfaces within 10' of the building foundation shall be sloped a minimum of 2% away from the building. [CBC 1804.3]	
19		Demonstrate handicap compliance for exterior spray booth building construction (i.e. handicap accessible route from public sidewalk to building entrances, handicap parking, handicap restrooms)	
<b>D. DESIGN AND CONSTRUCTION:</b>			
20		<p>a) The aggregate area of spray booths in a building shall not exceed the lesser of 10% of the area of any floor of the building or the basic area allowed for a Group H, Division 2 occupancy, without area increases. [CFC 2404.3.2.6]</p> <p>b) The area of any individual spray booth in a building shall not exceed the lesser of the aggregate size limit or 1500 square feet. [CFC 2404.3.2.6]</p> <p>c) Exception: One individual booth not exceeding 500 sqft. [CFC 2404.3.2.6]</p>	
21		When spray booth aggregate area exceeds 10%, the new room(s) must comply with H-2 occupancy requirements for deflagration hazards (i.e. fire separations, location, explosion venting, etc.). Additional corrections will be required.	
22		Spray booths shall be substantially constructed of steel not less than 18 gage in thickness for single-skin assemblies or 20 gage in thickness of each sheet for double-skin assemblies. Aluminum shall not be used. [CFC 2404.3.2.1]	
23		<p>All portions of spray booths shall be readily available for cleaning, and a clear space of not less than 3 feet around the booth shall be kept free of storage or combustible materials [CFC 2404.3.2.5].</p> <p>Exception: Spray booth can be located closer than 3 feet to or directly against an interior partition, wall or floor/ceiling assembly that has a fire resistance rating of not less than 1 hour or noncombustible material and the spray booth can be adequately maintained and cleaned.</p>	
24		Exit doors from pre-manufactured paint spray booths shall not be less than 30" wide by 80" in height. [CFC 2404.3.2.4]	
25		Indicate on plan that spray booths shall be protected by an approved automatic fire-extinguishing system. These systems shall be extended to protect exhaust plenums, exhaust ducts, and both sides of dry filters when such filters are used. [CFC 2404.4]	
26		The floor of the booth shall be noncombustible, nonsparking material. [CFC 2404.3.2.3]	
27		Indicate on floor plan the location of required portable fire extinguisher. [CFC 2404.4.1]	
<b>E. GENERAL NOTES:</b>			
<b><u>Print on plan the following required general notes:</u></b>			
28		Smoking shall be prohibited in spray finishing areas and in the vicinity of dip tanks. "NO SMOKING" signs shall be conspicuously posted in such areas. [CFC 2403.2.6]	
29		Welding warning signs shall be posted in the vicinity of spraying areas, dipping operations, and paint storage rooms with the following warning: "NO WELDING — The use of welding and/or cutting equipment in or near this area is dangerous because of fire and explosion hazards. Welding and cutting shall be done only under	

		the supervision of the person in charge". [CFC 2403.2.7]	
30		Electrical wiring and equipment shall be in accordance with 2013 CFC Chapter 24 and the 2013 California Electrical Code. [CFC 2403.2.1]	
31		Interior surfaces of spray booths shall be smooth; shall be constructed so as to permit the free passage of exhaust air from all parts of the interior, and to facilitate washing and cleaning; and shall be designed to confine residue within the booth. Aluminum shall not be used. [CFC 2404.3.2.2]	
32		Floors shall be of noncombustible material or shall be covered with a noncombustible, nonsparking material to facilitate cleaning operation in spray booths. [CFC 2404.3.2.3]	
33		When spray booths are illuminated, fixed lighting units that transmit light into the spray booth through heat-treated or hammered wire glass shall be used. Glass panels shall be arranged to minimize breakage and so that normal accumulation of residue on the exposed surface of a panel will not be raised to 200°F by the heat from the source of the illumination. [CFC 2404.6.2.1]	
34		Portable electric lamps shall not be used in spraying areas during a spraying operation. [CFC 2404.6.2.4]	
35		Open flames and spark-producing devices shall not be located in flammable vapor areas and shall not be located within 20' of such areas unless separated by a permanent partition. [CFC 2403.2.2]	
36		Metal parts of spray booths, exhaust ducts, and piping systems conveying Class I or Class II liquids shall be electrically grounded in accordance with the 2013 California Electrical Code. [CFC 2403.2.5]	
37		Spraying areas shall be provided with mechanical ventilation adequate to prevent the dangerous accumulation of vapors. [CFC 2404.7]	
38		Mechanical ventilation shall be kept in operation at all times while spraying operations are being conducted and for a sufficient time thereafter to allow vapors from drying coated articles and finishing material residue to be exhausted. [CFC 2404.7.1]	
39		Spraying equipment shall be interlocked with the ventilation of the spraying area such that spraying operations cannot be conducted unless the ventilation system is in operation. [CFC 2404.7.1]	
40		Recirculation ventilation systems shall have approved vapor detection systems. If the approved vapor concentration in the recirculated air stream exceeds 25 percent of the lower flammability limit, the system shall automatically shut down the spraying operation, switch the ventilation system to 100 percent outdoor exhaust and sound an alarm. [CFC 2404.7.2]	
41		Ventilation systems shall be designed, installed and maintained such that the average air velocity over the open face of the booth, or booth cross-section, in the direction of airflow during spraying operations shall not be less than 100 feet per minute. [CFC 2404.7.3]	
42		Portable fire extinguishers shall be provided for spraying areas in accordance with the requirements for an extra (high) hazard occupancy. [CFC 2404.4.1]	
43		Spray booths and spraying rooms shall not be alternately used for the purpose of drying arrangements which would cause a material to increase the surface temperature of the spray booth or room except in accordance with Section CFC 2404.6.1.1 and 2404.6.1.2. [CFC 2404.6.1]	

<b>F. VENTILATION:</b>		
44		Provide roof plan showing: a) Locations of spray booth exhaust outlet termination. b) Distance from exhaust outlet to property lines, to parapet wall, and height above ground.
45		Openings shall not be through wall that is required to be protected due location on property. [CBC Table 602]
46		Openings through roof shall not be closer to a property line for opening that is not permitted due to location on property line. [CBC Table 602]
47		Each booth shall have an independent exhaust system discharging to the outside. [CFC 2404.7.5]
48		Multiple spray booths having a combined frontal area of 18 sqft or less are allowed to have a common exhaust when identical spray finishing material is used in each booth. [CFC 2404.7.5]
49		If more than one fan serves one booth, fans shall be interconnected such that all fans will operate simultaneously. [CFC 2404.7.5]
50		Electric motors driving exhaust fans shall not be placed inside booths or ducts. Fan rotating elements shall be nonferrous or non-sparking or casings shall consist of or be lined with such material. Belts shall not enter ducts or booths unless belts and pulleys within a duct or booth are tightly enclosed. [CFC 2404.7.7]
51		Exhaust ducts shall be constructed of steel having a thickness in accordance with California Mechanical Code (CMC) Table 506.2(1) or Table 506.2(2).
52		The termination point for exhaust ducts shall be not less than the following [CMC 506.9]: 1) Ducts conveying explosive or flammable vapors, fumes, or dust: a) 30' from property line b) 10' from openings into the building c) 6' from exterior walls or roofs d) 30' from combustible walls or openings into the building that are in the direction of the exhaust discharge e) 10' above adjoining grade 2) Other product-conveying outlets: a) 10' from property line b) 10' from openings into the building c) 3' from exterior walls or roofs d) 10' above adjoining grade
53		Provide detail of exhaust duct penetration at roof showing duct size, gage, clean outs, supports, clearances, flashing, bracings, etc.
54		Exhaust ducts shall have a clearance from combustible construction or material of not less than 18 inches. [CMC 506.7]
55		Specify type of protection used to reduce duct clearance per CMC Table 506.7.
56		When combustible construction is provided with specified form protection applied to all surfaces within 18 inches of the exhaust duct, clearances shall not be less than those indicated on CMC Table 506.7. [CMC 506.7 exception 2]. Provide detail to illustrate.
57		There shall be at least 1" between the wall protector and combustible walls and ceiling for clearance, reduction systems using a ventilated space [CMC 506.7.2]. Provide detail to illustrate.
58		Duct support shall not exceed 12' spacing for 8" ducts nor 20' for larger ducts [CMC 506.5]. Provide detail & specify type duct

		support.	
59		For fan motors and belts [CFC 2404.7.7]: a) Electric motors driving exhaust fans shall not be placed inside booths or ducts. b) Fan rotating elements shall be nonferrous or nonsparking material. c) Belts shall not enter the duct or booth unless the belt and pulley within the duct are tightly enclosed.	
60		Makeup air shall be provided to replenish air exhausted by the ventilation system. Makeup-air intakes shall be located so as to avoid recirculation of contaminated air. [CMC 505.3]	
61		Provide accessible cleanouts at 10' interval and at changes in direction. [CMC 506.3]	
62		Ducts conveying explosive or <u>flammable vapors</u> , fumes, or dusts shall extend directly to the exterior of the building without entering other spaces and shall not extend into or through ducts or plenums. [CMC 505.1]	
63		Exhaust duct shall not be installed at an angle exceeding 45 degrees. [CMC 506.3]	
		<b>G. FIRE PROTECTION:</b>	
64		Spray booths and spraying rooms shall be protected by approved automatic fire-extinguishing systems. These systems shall be extended to protect exhaust plenums, exhaust ducts, and both sides of dry filters when such filters are used. [CFC 2404.4]	
		<b>H. STRUCTURAL:</b>	
65		Provide roof framing detail at roof penetration. Specify framing member sizes, hangers, etc. Framing at opening must be double headed and doubled joists.	
66		Exhaust vent at roof must be braced and guyed to prevent lateral and horizontal displacement.	
67		Provide structural plans, details, and calculation for any spray booth over 500 sqft in size.	
		<b>I. ELECTRICAL:</b>	
68		<b>Areas Subject to Overspray Deposits</b> – Electrical equipment <u>in spraying areas</u> that is located such that deposits of combustible residues could readily accumulate shall be specifically approved for locations containing deposits of readily ignitable residue and explosive vapors. [CFC 2403.2.1.4]	
69		<b>Areas Not Subject to Overspray Deposits</b> – Electrical wiring and equipment not subject to deposits of combustible residues but <u>located in a spraying area</u> shall be of an explosion-proof type approved for use in a Class I, Division 1 hazardous located in accordance with the California Electrical Code (CEC). [CFC 2403.2.1.2 and CEC Article 516]	
70		<b>Class I or Class II, Division 1 Locations</b> [CEC 516.3(B)]: 1) All interior locations of spray booths 2) All interior portions of exhaust ducts. 3) All areas in the direct path of spray operations.	
71		<b>Class I or Class II, Division 2 Locations</b> [CEC 516.3(C)]: 1) Locations outside of spraying operations conducted within a closed-top, open-face, or open-front booth extending from the edge of the open-face or open-front of the booth as follows:	

