



**NOTES:**

- ① PAINT INSIDE AND OUTSIDE OF ENCLOSURE WITH PRIMER AND FINISH COAT PER THE MANUFACTURER'S APPLICATION INSTRUCTIONS, 2.5 MILS. MINIMUM EACH (ONLY FOR STEEL ENCLOSURE).
- ② PAINT COLOR IS DESERT SAND OR BAJA BEIGE.
- ③ LOCATION OF UNIVERSAL AIR RELEASE VALVE ASSEMBLY WILL BE DETERMINED BY THE CITY INSPECTOR AT THE TIME OF INSTALLATION.
- ④ SIZE OF UNIVERSAL AIR RELEASE VALVE ASSEMBLY WILL BE DETERMINED BASED ON ENGINEERING CALCULATIONS AND BE SHOWN ON PLANS.
- ⑤ ALL FITTINGS TO BE THREADED FROM GATE VALVE AT MAIN TO THE AIR RELEASE VALVE.
- ⑥ 15" BEHIND BACK OF SIDEWALK WHEN SIDEWALK IS ADJACENT TO CURB, OTHERWISE MINIMUM 15" BEHIND BACK OF CURB, OR AS DIRECTED BY CITY ENGINEER.



APPROVED BY:		10.5.15	
<i>[Signature]</i>		44485	
LOUIS ABI-YOUNES, CITY ENGINEER	RCE	DATE	
RECOMMENDED:		9/17/15	
<i>[Signature]</i>		62268	
DENNIS MEJIA, UTILITIES ENGINEERING DIRECTOR	RCE	DATE	
REV	DESCRIPTION	BY	APP'D DATE

<b>CITY OF ONTARIO</b>	
<b>2" AIR RELEASE AND VACUUM RELIEF VALVE ASSEMBLY</b>	
STANDARD DRAWING NUMBER	<b>4102</b>