



NOTES:

- ① PAINT INSIDE AND OUTSIDE OF ENCLOSURE WITH PRIMER AND FINISH COAT PER THE MANUFACTURER'S APPLICATION INSTRUCTIONS, 2.5 MILS. MINIMUM EACH. ONLY FOR STEEL ENCLOSURE.
- ② PAINT COLOR IS DESERT SAND OR BAJA BEIGE.
- ③ LOCATION OF UNIVERSAL AIR RELEASE VALVE ASSEMBLY WILL BE DETERMINED BY THE CITY INSPECTOR AT THE TIME OF INSTALLATION.
- ④ SIZE OF UNIVERSAL AIR RELEASE VALVE ASSEMBLY WILL BE DETERMINED BASED ON ENGINEERING CALCULATIONS. SIZE TO BE SHOWN ON PLANS.
- ⑤ ALL FITTINGS TO BE THREADED FROM CORP. STOP AT MAIN TO THE AIR RELEASE VALVE.
- ⑥ 15" BEHIND BACK OF SIDEWALK WHEN SIDEWALK IS ADJACENT TO CURB, OTHERWISE MINIMUM 15" BEHIND BACK OF CURB, OR AS DIRECTED BY CITY ENGINEER.



| | | | |
|--|-------------|---------|------------|
| APPROVED BY: | | | |
| <i>Louis Abi-Younes</i> | | 10-5-15 | |
| LOUIS ABI-YOUNES, CITY ENGINEER | | 44485 | RCE DATE |
| RECOMMENDED: | | | |
| <i>Dennis Mejia</i> | | 9/17/15 | |
| DENNIS MEJIA, UTILITIES ENGINEERING DIRECTOR | | 62268 | RCE DATE |
| REV | DESCRIPTION | BY | APP'D DATE |
| | | | |

| | | |
|--|--|--|
| CITY OF ONTARIO | | STANDARD DRAWING NUMBER 4103 |
| 1" AIR RELEASE AND VACUUM RELIEF VALVE ASSEMBLY | | |
| | | |