



CITY OF ONTARIO

Landscape Planning Division

Senior Landscape Planner
Associate Landscape Planner

909/395-2237
909/395-2615

Landscape Development Guidelines

Requirements and guidelines for Landscape Plans and Installation

I. Landscape Plan requirements for Development Advisory Board (DAB)

A. Landscape Design Requirements

1. Water conservation is a high priority in the City of Ontario. Landscapes shall be designed to use water efficiently without waste to the lowest practical amount and comply with the State's current Model Water Efficient Landscape Ordinance. Sources for low water plants are WUCOLS, "Water Use Classification of Landscape Species" <http://www.owue.water.ca.gov/docs/wucols00.pdf> , or other approved scientific source.
2. Landscape areas shall be composed of living plant materials spaced no greater than the mature diameter of each plant. Non-living ornamental features (boulders, gravel, dry stream beds, etc) may comprise up to 5% of the landscape and shall be a pervious material.
3. Warm season turf may be used for recreational use projects (parks, sports fields, etc. where turf provides a playing surface) and residential projects with a maximum 25% of the landscape. Planter areas irrigated by spray shall not be less than 10' wide. Low water use groundcovers shall be used in traditional turf areas; parkways, etc.
4. Design landscapes and irrigation for use with recycled water where available. New multi-family residential projects shall use recycled water for HOA maintained property (parks, parkways, neighborhood edges, common areas). Single family projects and swimming pool areas enclosed by fencing shall use potable water for on-site irrigation.
5. Recycled water irrigation systems shall provide a physical separation between areas irrigated with potable water by means of a wall, fence, paving or in landscape areas a mow curb with irrigation lines or heads no closer than 24' on each side for spray and 12" for drip.
6. All landscaped areas adjacent to paving shall be bordered by a concrete or masonry curb, or other approved means, to prevent vehicles from entering landscape areas. Curbs along pavement may have openings to allow water infiltration into landscape areas.
7. Concrete mowstrips are required at turf areas adjacent to landscape planters and to separate adjacent properties or maintenance responsibility areas. Redwood header boards are allowed for individual single family home projects and to define the lot line adjacent to undeveloped property.

8. All utilities shall be shown on the plans and coordinated with the landscape design and tree placement. Utilities such as backflow devices and transformers shall be located a minimum distance of 3 feet away from paving or other utilities to allow for landscape screening to cover at least 75 percent of the height of the equipment. Paint brass backflows green RAL 6009 Fir Green or equal. Transformers shall be set back 5' from paving and drive aisles and include a planted groundcover in front.
9. Accent landscape (single or multi-trunk specimen trees) are required on all Commercial or Industrial corners, including vehicular entries and major corner intersections. All accent trees shall be min. 36" Box. Palms shall be min. 17' brown trunk height (BTH) and minimum 4' cubed rootball.
10. Foundation planting adjacent to building (hedgerows or shrub masses in a hierarchy pattern) is required at major building perimeters and residential front yards to break horizontal ground plane from the vertical plane of building.
11. Plants at monument signs shall be a hierarchy of ornamental shrubs or perennials.
12. Landscape areas shall have a minimum inside dimension of five feet (5') wide to include trees. Six (6') width minimum is required for planters with vegetated swales.
13. Parking areas visible from public streets or adjacent parcels shall be screened with landscaping three feet (3') minimum height, and shall be located to allow for two feet overhang of vehicles unless wheel stops are provided.
14. Parking lots shall have canopy shade trees in landscape islands one for every 10 spaces single row and one for every 5 spaces per double row. Parking lot double rows shall have a center planter strip 5' wide which may include an infiltration trench, where possible. Canopy shade trees shall have a minimum canopy diameter of 30'.
15. Parking lot landscaping shall maximize broad canopy shade tree planting to reduce heat gain on paving and buildings. Add large planters, center planter strips or diamond planters between parking rows for shade trees.
12. Planters adjacent to parking stalls shall have a 12" wide curb for access to vehicles.
13. Landscape areas shall be bounded by concrete curbs six inches high except for openings into infiltration basins or swales.
16. Trash enclosures shall have adjacent planters with trees, shrubs and vines to screen.
17. Parkways and right-of-ways shall be landscaped with living plant material less than 18" high, automatically irrigated and contain street trees per the Master Street Tree Plan spaced 25'-35' apart and coordinated with utility setbacks.
15. Undeveloped areas within the project site shall be seeded with wild flower or ornamental grass mix and automatically irrigated to prevent soil erosion from rain and strong winds
16. Projects with landscape within Caltrans ROW's shall develop a co-operative agreement with Caltrans San Bernardino for landscape installation and maintenance.
17. Wireless facilities shall be screened with groupings (min 3) of approved live trees and shrubs to blend the facility with adjacent tree or palm stands. California native trees and shrubs are preferred. Tree size shall be minimum 2/3 the height of the facility or as Landscape Planning Department approved. Permanent irrigation and regular maintenance shall be provided for landscaping.

18. Additional requirements of a Specific Plan may be required based upon the project location. If in doubt of the Specific Plan in your area, contact the Planning Dept.
19. Plant selection and irrigation design shall be appropriate with Ontario's regional climate (Zone 18) classified as Mediterranean, and characterized by hot, dry summers and mild winters. Winter temperatures average between 60 to 70 degrees with occasional lows in the 20's. Summers average 75 –90 degrees with highs exceeding 100 degrees. Average yearly rainfall is approximately 16 inches. Winds develop from the southwest averaging 6 mph. Hot, dry Santa Ana winds occur between October to March from the northeast at 30 mph with gusts at 60mph and more. Air quality is considered poor due to frequent temperature inversions trapping pollutants below the inversion.

B. Preliminary Landscape Plans shall include:

1. Site features identified: streets, right-of-ways, property lines, hardscape, walls, fences, trash enclosures, swales and detention basins. Coordinate with Engineer.
2. Site utilities identified: water meters, backflow devices (fire, domestic and irrigation), fire hydrants, light standards, power poles, vaults, transformers, manholes, utility lines and easements.
3. Existing tree symbols identifying genus, species and trunk diameter at 4.5' above grade. Existing trees of quality shall be protected and planter areas shall be designed to the extent of the drip line. A tree report shall be provided by a qualified landscape architect or certified arborist for trees on site proposed to be removed. Replacement trees shall be specimen sized: 60" box or as approved. 2 new trees for each removed.
4. Street trees; identify genus; note existing or proposed trees; minimum size 24" box; space 25'-30' OC (on center). Verify type with the Landscape Planning Division.
5. Proposed trees; identify genus and container size per the Minimum Quantity, Size and Species Mix charts (Section F) and note for screening, shade or accent.
6. Locate deciduous trees on the south and west sides of building and evergreen trees on the north and east for passive heat and cooling and to serve as a wind break where possible.
7. Shrub areas; identify with symbol, hatch or stipple and list genus and species.
8. Include square footage of total landscape area.
9. The Maximum Applied Water Allowance (MAWA) calculation shall be based upon the area devoted to landscaping as shown on the preliminary landscape plan. See Water Budget, Section II.
10. Note for protection and preservation of native species, where possible.
11. Turf area and edge restraint; identify. Warm season turf preferred for recreational use only. Low water groundcovers may be used in traditional turf areas; parkways, etc.
12. Note for an automatic irrigation system to be installed that is water efficient, appropriate for the landscape hydrozones and provides 100% coverage.
13. Conceptual irrigation exhibit indicating sleeve locations crossing streets; irrigation service meter locations and area served by potable and/or recycled water.
14. Landscape areas shall be designed to provide opportunities for storm water infiltration and retention so that all irrigation and normal rainfall remains within property lines and

does not drain on to non-permeable hardscapes to recharge groundwater and improve water quality. Coordinate with grading plans.

15. Hardscape designs shall assist on-site stormwater infiltration with permeable paving for parking, driveways, gutters or asphalt roadways, where possible.

II. Landscape Construction Documents

A. Plan Check Submittal Procedures

1. The Developer /Applicant shall furnish two sets of Landscape Construction Documents for the first submittal. Add one additional set for recycled water projects.
2. Sets shall be submitted to the Building Department at the same time that the Architectural Construction Documents are submitted for plan check. Note on plans the project permit number provided with Architectural or Civil submittal. The review of the landscape package is done by the Landscape Planning Division; therefore, the sets should be separately bound from the Architectural Package.
3. Development requiring a permit shall have landscape construction documents prepared by a state registered landscape architect
4. All sheets shall be wet signed by the Landscape Architect and include the license number and the expiration date.

B. Contract Document Sheets

1. Construction Plan (shall include hardscape, mowstrips, raised planter walls, etc.)
2. Irrigation Plan
5. Planting Plan
6. Detail Sheet(s) Sections and elevations for trash enclosures, monument signage, or fencing shall be included in the detail sheet. (If obtained from the architect shall note name, address, and phone number.)
7. Specifications for construction, landscape, and irrigation plans.
8. See Urban Tree Foundation or similar scientific source for tree planting details.
9. Grading and Utility Plans (from Architect or Engineer). Landscape Plans will not be signed off for building permits until grading plans are approved.

C. Format

1. Sheet size: 24"x 36" min., north arrow with north at top of page or to the right.
2. Scale: 1:10, 1:20, or 1:8.
3. Text and symbols shall be 1/8", capital letters and legible for reproduction at 11"x17".
4. Landscape areas that are to be maintained by the City of Ontario (master planned streets, parkways, medians, maintenance districts, parks, trails etc.) shall be on City of Ontario title block available from the Engineering Department. As-built sets shall be on Mylar and submitted to the Engineering Dept.

D. Title Sheet

1. Project name, address, and Development Advisory Board (DAB) Number (obtain from Architect or Owner).

2. Vicinity map with north reference
3. Developer's name
4. Landscape Architect's name, address and telephone, license number, expiration date, and signature (wet signed)
5. Other consultant's name and address, and telephone.
6. Sheet index and key map (if applicable)
7. Date stamped (printing date and revision date)

E. Irrigation Plan

1. The irrigation plans and components shall be designed to be water efficient and effective for the landscape proposed. Plans shall include a water budget with Maximum Applied Water Allowance (MAWA) and Estimated Total Water Use (ETWU) calculations shown on landscape construction documents. The ETWU shall not exceed the MAWA. Show the Water Use schedule.
2. Automatic irrigation controllers and sensors utilizing either evapo-transpiration or moisture sensor data utilizing nonvolatile memory are required. Verification letter from the manufacturer for proper installation may be required prior to acceptance of the project.
3. Irrigation systems shall be designed with like plant material grouped together and proper solar orientation. Turf shall be on a separate valve from shrub areas. Landscape areas in the shade (north or east sides of buildings) shall be controlled separately from areas in the sun (south or west). Trees shall be on a separate system. The irrigation system must be designed to conform to the hydrozones of the landscape plan. Hydrozones shall be shown on the landscape and irrigation plan and be designated by Number, Letter or Hatching symbol.
4. Provide on plans the point of connection (POC) all equipment required, sizes, notes and details, include water meter (note potable or recycled water), static pressure, and maximum GPM.
5. Contact the City's Utilities Department for City main pressure. Pressure regulating or boosting devices shall be installed to meet the pressure requirements of the system or refer to the City of Ontario website: Engineering department, design guidelines/ Master Plans Ultimate system for potable water or Capital Improvement Programs for recycled water maps with City Main Pressure Zones, or call 909 395-2678.
6. Indicate size of manual shutoff valves, and locate close to the point of connection to minimize water loss in case of an emergency.
7. Indicate size and location of flow sensors and master valves to detect high flows on all nonresidential landscapes and residential landscapes of 5,000 SF for more.
8. Indicate size and location of reduced pressure backflow devices, pressure regulating valves (required on recycled water systems), automatic remote control valves, quick couplers, automatic controllers and rain sensors. Backflow devices, pipe and fitting shall be brass or bronze and painted green and protected in a locking enclosure. RP devices shall be brass pipe and fittings and accessible for testing.
9. Irrigation equipment legend shall include: symbol, manufacturer, model number, nozzle size, radius, gpm, psi, pattern (45, 90, 180 degrees, etc.) precipitation rate and detail.

10. Spray heads shall have matched precipitation rates. Pop-ups shall be 6" for lawn, low groundcover or parked car overhang areas, 12" for shrub areas. Heads on risers are only allowed adjacent to walls with limited space for pop-ups.
11. Spacing design for irrigation spray heads shall achieve 100 percent coverage, (head to head). Allow for wind velocities. Heads shall must document a distribution uniformity low quarter of 0.65 or higher per ASABE/ACC 802-2014.
12. Locate spray heads 24" from non-pervious paving to prevent overspray. Exception allowed if adjacent surface is permeable or if using alternative technology irrigation. Rotator or rotary heads maybe located 12" from paving.
13. Narrow or irregularly shaped areas including turf, less than 10 FT in any direction shall be irrigated with subsurface irrigation or a low volume irrigation system. Low precipitation heads, rotators or drip systems shall be used in general to reduce water use and overspray.
14. Slopes greater than 25% shall not be irrigated with a spray system with an application rate exceeding 0.75 inches per hour.
15. Include check valves or anti-drain valves to prevent low head drainage.
16. All trees shall have pop-up stream bubbler heads. Trees in tree wells or permeable paving shall have pop up stream bubblers or bubblers in a maximum 18" deep perforated root watering tube where overspray may occur. Add gravel to tube to slow infiltration where needed. Tree irrigation shall be on a separate valve, min. 2 heads per tree. Drip line shall be outside of trunk flare min 3' diameter.
17. Narrow or irregularly shaped areas including turf, less than 10' in any direction shall be irrigated with subsurface irrigation or a low volume irrigation system. Low precipitation heads, rotators or drip systems shall be used in general to reduce water use and overspray.
18. Size all irrigation main lines and laterals on the plan, minimum size $\frac{3}{4}$ ".
19. Irrigation lateral lines shall be Sch 40 PVC. All pressure main line shall be Sch 40 PVC for sizes up to 1½" diameter. Class 315 PVC for lines 2" and larger.
20. Under landscape, mainlines shall be buried with 18" min. cover, laterals 12" min. cover.
21. Under paving mainlines shall be buried with 24" min. cover; lateral lines 18" min. cover.
22. Pipe under roadways shall be installed 36" deep, sleeved and identified with marking tape installed 12" from the surface identifying type of line with APWA standard "Caution waterline buried below" in blue or "Caution recycled waterline buried below" in purple. Sleeves shall be Schedule 40 PVC, two times the diameter of the pipe being sleeved.
23. Recycled water irrigation systems shall provide a physical separation between areas irrigated with potable water by means of a wall, fence, paving or in landscape areas a mow curb with pipe and heads set back 24" or a 12" setback for drip line each side.
24. New residential projects shall use recycled water for HOA maintained property (parks, parkways, neighborhood edges, common areas). Potable water with a backflow shall only be used on single family detached properties even if HOA maintained.
25. Label each valve system with valve number, valve size, gpm, sq ft. and plant type.

26. Automatic Controllers shall contain a neatly drawn laminated irrigation layout chart, color coded to identify stations and valves as-built. Central controller shall include a manufacturer support page. Locate pedestals within planter areas with an 18" pad of DG or mulch at front for access.
27. An irrigation schedule shall be on the plan and layout chart noting irrigation cycles and run times per station or plant type (turf, shrub, trees, sun areas, shade areas, etc.) monthly or seasonally. Add multiple start times to prevent run off. Watering shall occur during the night hours when winds are calm excepting drip irrigation
28. Irrigation systems budget shall have an irrigation audit performed by a certified landscape irrigation auditor and submit report to the Approving Authority to include: inspection, system tune-up or repair, system test with distribution uniformity for spray systems, correction of overspray or run-off, and preparation of an irrigation schedule and set up of the irrigation controller.
29. Water features and decorative fountains shall use recycled water in commercial and industrial projects, potable water in residential projects.
30. Include all details, notes and specifications.

F. Soil testing

1. Agronomical soil testing shall be performed to encourage healthy plant growth and reduce run off. One test shall be performed for each street frontage, multiple landscape installations or production home developments shall sample 1 in 7 lots or as otherwise required by the Approving Authority.
2. Soil analysis shall include soil texture, infiltration rate, pH, total soluble salts, sodium, percent organic matter, and recommendations for amendments based upon the proposed plant material and tree types.
3. Soil test results and recommendations for amendments shall be listed on the Landscape Planting Plan required pursuant to Paragraph 6.05.015.B.5 (Landscape Planting Plan) of this Division, noting the name, address, telephone number of the City-approved soils testing laboratory, and the test date.
4. Proof of amendments purchased and installed may be required at inspection.

G. Planting Plan

1. Legend shall include: symbol, botanical name (genus, species and variety), common name, size, quantity, and detail reference. Include any existing trees.
2. Minimum tree planting setbacks:
 - 25' from beginning of curb returns at street intersections
 - 10' from light standards, power poles and fire hydrants
 - 7' from water and sewer lines
 - 5' from sidewalks (except in parkways), driveways, and buildings
3. Show corner sight line distances (Engineering Dept. Std Dwg # 1309) on the planting plan.
4. The minimum mix of tree sizes and species shall be provided as follows and shall conform to the following minimum measurements (individual single family home projects excluded). A minimum of 20% of the total number of trees shall be California native species appropriate for the project site.

<i>Minimum Tree Quantity and Size Specifications (Palms are not included)</i>				
<i>Minimum on-site Trees</i>	<i>Size</i>	<i>Trunk Caliper</i>	<i>Height</i>	<i>Spread</i>
5%	48-inch box	3.50-inches	14 to 16 FT	7 to 8 FT
10%	36-inch box	2.50-inches	12 to 14 FT	6 to 7 FT
30%	24-inch box	1.50-inches	9 to 11 FT	4 to 5 FT
55%	15-gallon	1.0-inch	7 to 8 FT	2 to 3 FT

<i>Minimum Tree Species Mix (Palms are not included)</i>	
<i>Number of Trees</i>	<i>Minimum Number of Tree Species Required</i>
20 or Fewer	3
21 to 30	4
31 to 40	5
More than 40	6

5. Existing trees (show on plan) shall be protected in place wherever possible. Large canopy existing trees may be used for the 48" box size requirement. Add tree protection notes to plans. A tree report is required if existing trees are to be removed. Identify genus, species, trunk diameter (dbh), health condition and reason for removal. Transplant trees when weather is suitable or contact a tree broker or transplant specialist. Replacement trees for trees removed shall be 60" or 48" box size, two new for each removed or as approved by the Landscape Planning Division.
6. Trees shall be planted 2"-3" higher than the existing grade. The trunk flare and top root shall be visible. No soil or mulch shall be placed on top of the rootball. Trees with kinked or girdling roots shall be replaced. Shade trees shall have a single dominant leader. See <http://hort.ifas.ufl.edu/woody/planting.html>
7. Street trees shall be 24" box for all new residential tracts, commercial, and industrial projects in Ontario. Replacement of street trees in established residential areas may be fifteen (15) gallon. Provide one tree for twenty five to thirty five feet (25'-35') of linear property frontage. Street trees shall have a mulch only area min. 6' diameter.
8. Trees wells shall be min. 4' wide by 6' long as space allows. Iron tree grates shall be Kiva (Urban accessories) Starburst (Iron Smith) or approved equal with 3/8" max slots per ADA guidelines, with 30" center opening to allow stakes, and flat black rustoleum coating. 3" of uncompacted, non-stabilized decomposed granite (DG) may also be used in tree wells as approved.

9. Fifteen (15) gallon and larger trees shall be double staked perpendicular to prevailing wind or parallel to the street. Stakes shall be minimum 7'-8' above grade, 3'-4' below, and tied to the canopy for wind protection. Locate to prevent branch damage.
10. Box trees 36" or larger shall be triple guyed or triple staked. Rootball staking or guying (Duckbill system from Earth Anchor or equal) is also acceptable.
11. Tree ties shall be flexible such as V.I.T. Wonder ties, Cinch ties, or approved equal. Wire and hose or metal rod type braces are not permitted. Nursery stakes shall be loosened if to remain during maintenance and removed by end of maintenance.
12. Linear root barriers if proposed, shall be 12" deep maximum for trees planted within 5' of paving. Root barriers shall not surround any tree but shall run parallel to paving.
13. Shrubs shall be five (5) gallon container size min. and are to be spaced max. 2/3 of mature size. One (1) gallon containers may be used for perennials and groundcovers.
14. Shredded mulch within planter areas is required at a depth of 3" for shrubs and 1" for groundcover. Shredded bark with a tackifier shall be used on 3:1 slopes or greater, not wood chips. Soil shall not be visible. Keep mulch 3" clear of plant stem, 6" of trees.
15. Slopes 3:1 or greater require jute netting with groundcover, shrubs or ornamental grasses. Turf grass is not allowed on slopes greater than 3:1. Slopes greater than 4:1 shall not be irrigated with an irrigation system with a precipitation rate exceeding 0.75 inches per hour.
16. Groundcovers from flats shall be spaced at 10" on center. Low groundcovers shall not exceed an 18" width in front of larger shrubs. One (1) gallon containers shall be used for larger groundcover areas. Perennials or annual color shall be spaced at 8".
17. Note on plans for a pre-emergent to be applied before the mulch layer is installed to prevent weeds. Weeds shall be removed before 2" high or weed seeds develop.
18. Details, Notes and Specifications.
19. Maintenance shall be permanently provided for all areas, including parkways and determined setbacks, not designated for paving, sidewalk, or building. Identify who is responsible for continued maintenance; HOA, LMD or property owner. Irrigation system shall function properly and landscaping maintained in a healthy condition.
20. A Maintenance Schedule shall be located on the irrigation controller layout chart. Schedule shall include but not be limited to: watering; routine inspection; adjustment and repair of the irrigation system and its components; aerating and dethatching turf; replenishing mulch; fertilizing; pruning; weeding in all landscape area and cleaning irrigation nozzles. See section K.
21. City maintained projects shall include a maintenance period of one year after city approval. Contact the City Parks Department for recommendations, 909 395-2600
22. Irrigation for newly planted trees shall be light and frequent through the establishment period (6-12 months per 1" caliper). Provide 2 to 2 1/2 gallons of water per 1" of caliper at every irrigation on the following schedule:
 - a. < 2" caliper: Irrigate daily for 2 weeks, then every other day for 2 months, then weekly until established.
 - b. 2-4" caliper: Irrigate daily for 1 month, then every other day for 3 months, then weekly until established.

- c. >4" caliper: Irrigate daily for 6 weeks, then every other day for 5 months, then weekly until established.

23. Prior to final City inspection, the Landscape Architect shall inspect for compliance to approved plans. Submit the Certificate of Completion to the Landscape Planning division. City facilities or city contractor maintained projects shall be contractor maintained for minimum 90 days after inspected and approved.

H. Water Efficient Landscape Worksheet

1. A project applicant shall complete the Water Efficient Landscape Worksheet in Appendix A which contain information on the plant factor, irrigation method, irrigation efficiency, and area associate with each hydrozone.
2. The Maximum Applied Water Allowance (MAWA) is calculated based on the maximum Evapotranspiration adjustment factor (ETAF) allowed. The Estimated Total Water Use (ETWU) is calculated based on the plants used and irrigation method selected for the landscape design. ETWU must be below the MAWA.
3. The plant factor used shall be from WUCOLS*, or from horticultural researchers with academic institutions or professional associations approved by the California department of Water Resources. an estimate of the amount of water needed by plants, based upon the Department of Water Resources' Water Use Classification of Landscape Species. The applicable WUCOLS edition may be obtain online at <http://www.water.ca.gov/wateruseefficiency/landscape/>

* WUCOLS, Water Use Classification of Landscape Species published by California Cooperative Extension, the Department of Water Resources and the Bureau of Reclamation, 2000.

4. The plant factor ranges from 0 to 0.1 for very low water using plants, 0.1 to 0.3 for low water using planting, from 0.4 to 0.6 for moderate water use plants and from 0.7 to 1.0 for high water use plants.
5. Show hydrozones on the irrigation plan. Water features shall be included in the high water use hydrozone, and temporarily irrigated areas shall be included in the low water use hydrozone.
6. All Special Landscape Areas (SLA) means an area of landscape dedicated solely to edible plants, recreational areas, areas irrigated with recycled water or water feature using recycled water. The SLA shall be identified and water use calculated as shown in Appendix B.
7. A controller chart and irrigation plan shall show the hydrozones and shall be colored and laminated and included in the irrigation controller box.
8. Existing landscapes shall meet the water budget MAWA for Existing Landscape Areas using the higher 0.8 ET adjustment factor.
9. Existing landscape areas shall employ techniques, equipment and procedures to reduce water use to meet the water budget (MAWA) for existing landscapes, including:
 - Reprogram existing controller to correct run times and adjust monthly for temperature, sunlight and precipitation changes.
 - Install a weather-based controller or soil moisture sensor
 - Check for and repair any leaks in the irrigation system.
 - Replace high volume sprinkler heads with new low flow heads.

- Where applicable, convert sprinkler areas to drip irrigation.
 - Adjust spray pattern of existing sprinklers to eliminate overspray and runoff.
 - Replace existing turf grass or high water use landscaped areas with low water using shrub and groundcovers.
 - Replace or repair irrigation equipment as recommended by an irrigation survey or audit.
10. An irrigation audit for new and existing landscapes shall be performed by a Certified Landscape Irrigation Auditor and not the person who designed or installed the landscape. Large projects may use an auditing rate of 15% (for example, 1 in 7 production homes or project phases). Audits shall include inspection, report, verification of system repairs or tune up, preparation of an irrigation schedule and configuring the irrigation controller to meet the water budget.
11. The project applicant shall submit an Irrigation Audit report with the Certificate of Compliance prior to City inspection and permit sign off.

I. Grading design and stormwater infiltration

1. Grading shall be designed to minimize soil erosion, water run-off or water waste and increase on-site retention and infiltration. Include erosion control measures.
2. Grading shall be designed so that all irrigation and normal rainfall shall remain within property lines and not drain onto non-permeable surfaces. Finished grades for landscape areas shall be set at 1 ½” below finished surfaces.
3. Landscaped slopes shall incorporate erosion control products and groundcover, shrubs, or ornamental grasses from containers and or hydroseed appropriate for slopes. Slopes shall be irrigated by a system with a low precipitation rate. Turf is not allowed on slopes greater than 4:1, or where the toe of the slope is adjacent to an impermeable hardscape.
4. Landscaped slopes shall be 3:1 or less and shall incorporate erosion control netting (jute mesh) or erosion control blankets (woven coconut coir fiber). Landscape areas receiving sheet flow or concentrated flow shall be reinforced with erosion control blanket and layers of rip rap or cobblestones on top of the blanket in a sufficient quantity and length to diffuse the flow.
5. Landscape areas shall be designed for storm water management with proper plant materials and irrigation to be successful in both saturated soils and dry conditions of storm water infiltration areas.
6. Stormwater collection shall direct water into depressed landscape areas such as: vegetated swales, detention basins, infiltration area, french drains or manufactured drywells or storage chambers to aid infiltration on each site.
7. Compaction during site grading shall not compact soil in landscape areas beyond 85% which inhibits proper plant growth.
8. Use pervious or porous pavements where possible to minimize run off.
9. Basins, swales and sloped grades for stormwater management shall incorporate a level area adjacent to paved edges at least 5’ in width, to allow utilities, such as backflow devices, to be located on level ground, and to serve as a buffer from sloped edges, for pedestrian safety purposes.

10. Basins, swales and sloped grades for storm water management within the required landscape areas (not a separate area for storm water management) shall not be greater than 40% of the area width if depth is 3:1 or greater.
11. A Bioretention Soil Mix (BSM) for basins and swales shall infiltrate surface water, support plant growth and provide pollutant treatment. The following includes the measurement for determining the BSM by volume and weight:

BSM Composition	Sand	Sandy Loam			Compost
		Sand	Silt	Clay	
Volume	65%	20%			15%
Weight	75-80%	10% max	3% max	9% max. *	

* 9% compost by weight results in approximately 5% organic matter by weight

A Soil Media Mix for Bioretention

- 85 to 88 % sand. Washed, medium sand
- 8 to 12 % fines. Fines include both clay and silt.
 - 12% to obtain 1 in/hr infiltration rate for nitrogen removal
 - 8% to obtain 2 in/hr infiltration rate for phosphorus, metal, and other pollutant removal
- 3 to 5 % organic matter.

J. Decorative Water Features

1. Decorative water features shall be properly maintained to operate and function to meet the intent of the design.
2. Decorative water features shall incorporate recirculating water systems, where possible.
3. Decorative water features, excluding swimming pools and spas, shall use recycled water, where available.

K. Planting Stock and Materials

1. All plants and tree installed within the city of Ontario shall conform with American Association of Standards, ANSI Z60.1 Specifications for Acceptance of Nursery Trees at the time of delivery, in all ways.
2. Plants shall be sound, healthy, vigorous and free of plant diseases and inspect pests and their eggs.
3. Containers stock shall not be root bound or have girdling roots.
4. Trees shall not have been topped or headed.
5. Plants and trees with broken branches or injured trunks shall be rejected

L. Maintenance Schedule

1. Include a maintenance schedule on the plans to direct the landscape maintenance of the site to include the following on a weekly basis
2. Add maintenance schedule to irrigation controller chart for placement in the irrigation cabinet. Schedule shall include

- Irrigation schedule;
- Weed control;
- Monitoring and treatment for pests, disease or injury;
- Mowing and edging
- Pruning and the removal and timely replacement of dead or dying plants;
- Fertilizing; include soil report maintenance fertilizer recommendations.
- Clearing of trash or debris;
- Repair and/or timely replacement of irrigation systems, and components thereof;
- Repair and/or timely replacement of integrated architectural features; and
- Any other similar act(s) that promotes growth, health, beauty, and the life of plants, shrubs, trees, and/or groundcover/turf

M. Water Conservation Statement

Permit No: _____ Project Address: _____

Landscape Architect and License Number: _____

Certified Irrigation Designer and Certification Number: _____

Total Project Area: _____ Total Landscape Area: _____

Total Turf Area: _____ Total Active Recreational Area: _____

Total Permanent and Solely Dedicated to Edible Plants: _____

Total Non-irrigated Landscape Area: _____

Project Type (check only one):

- | | |
|---|--|
| <input type="checkbox"/> Public Facility (park, playground, etc.) | <input type="checkbox"/> Single Family Residential |
| <input type="checkbox"/> Commercial | <input type="checkbox"/> Multi- Family Residential |
| <input type="checkbox"/> Industrial | <input type="checkbox"/> Other |

Water Supply Type:

- | | | |
|----------------------------------|---|--------------------------------|
| <input type="checkbox"/> Potable | <input type="checkbox"/> Recycled water | <input type="checkbox"/> Other |
|----------------------------------|---|--------------------------------|

Included in this project submittal, are the following (check all that apply):

- | | |
|--|---|
| <input type="checkbox"/> Maximum Applied Water Allowance: _____ gallons/year | |
| <input type="checkbox"/> Estimated Total Water Use: _____ gallons/year | |
| <input type="checkbox"/> Landscape Design Plan | <input type="checkbox"/> Soil Management Plan |
| <input type="checkbox"/> Irrigation Design Plan | <input type="checkbox"/> Irrigation Schedules |
| <input type="checkbox"/> Precise Grading Plan | <input type="checkbox"/> Maintenance Schedule |

Project Description (briefly describe the planning and design actions that are intended to achieve conservation and efficiency in water use):

Prepared By: _____ Date: _____

N. Water Efficient Landscape Worksheet

Reference Evapotranspiration (ET_o) 54.6

Hydrozone Plant type	Plant Factor	Irrigation method	Irrigation efficiency	ETAF (PF/IE)	Landscape area sq.ft.	ETAF x Area	Estimated Total Water Use (ETWU)
Regular Landscape Areas							
				Totals	A	B	
Special Landscape Areas							
				1			
				1			
				1			
				Totals	C	D	
					ETWU Total		
MAWA (Annual Gallons Allowed) =ET _o x 0.62 x ETAF x Area					MAWA		
ETWU must be less than MAWA					Difference		

Hydrozone #/ planting type: lawn, shrub, native plants, trees.
Irrigation method: overhead spray or drip

ETAF Calculations: Average ETAF for Regular Landscape Areas must be 0.55 or below for residential areas and 0.45 or below for non-residential areas.

Regular Landscape Areas

Total ETAF x Area	(B)
Total Area	(A)
Average ETAF	B/A

ALL Landscape Areas

Total ETAF x Area	(B+D)
Total Area	(A+C)
Site Average ETAF	(B+D) / (A+C)

O. Prescriptive Compliance Option

1. This section contains prescriptive requirements which may be used as a compliance option to meet the requirements of the Model Water Efficient Landscape Ordinance.
2. Compliance with the following items is mandatory and must be documented on a landscape plan in order to use the prescriptive compliance option:
 - a. Submit a Landscape Documentation Package which includes the following elements:
 - i. date
 - ii. project applicant
 - iii. project address (if available, parcel and/or lot number(s))
 - iv. total landscape area (square feet), including a breakdown of turf and plant material
 - v. project type (e.g., new, rehabilitated, public, private, homeowner-installed)
 - vi. water supply type (e.g., potable, recycled, well) and identify the local retail water purveyor
 - vii. contact information for the project applicant and property owner
 - viii. applicant signature and date with statement, "I agree to comply with the requirements of the prescriptive compliance option to the MWELO".
 - b. Incorporate compost at a rate of at least four cubic yards per 1,000 square feet to a depth of six inches into landscape area (unless contra-indicated by a soil test); Soil test, report, and recommendations installed.
 - c. Plant material shall comply with all of the following;
 - i. For residential areas, install climate adapted plants that require occasional, little or no summer water (average WUCOLS plant factor 0.3) for 75% of the plant area excluding edibles and areas using recycled water; For non-residential areas, install climate adapted plants that require occasional, little or no summer water (average WUCOLS plant factor 0.3) for 100% of the plant area excluding edibles and areas using recycled water;
 - ii. A minimum three inch (3") layer of mulch shall be applied on all exposed soil surfaces of planting areas except in turf areas, creeping or rooting groundcovers, or direct seeding applications where mulch is contraindicated.
 - d. Turf shall comply with all of the following:
 - i. Turf shall not exceed 25% of the landscape area in residential areas, and there shall be no turf in non-residential areas;
 - ii. Turf shall not be planted on sloped areas which exceed a slope of 1 foot vertical elevation change for every 4 feet of horizontal length;

- iii. Turf is prohibited in parkways less than 10 feet wide, unless the parkway is adjacent to a parking strip and used to enter and exit vehicles. Any turf in parkways must be irrigated by sub-surface irrigation or by other technology that creates no overspray or runoff.
- e. Irrigation systems shall comply with the following:
- i. Automatic irrigation controllers are required and must use evapotranspiration or soil moisture sensor data and utilize a weather sensor.
 - ii. Irrigation controllers shall be of a type which does not lose programming data in the event the primary power source is interrupted.
 - iii. Pressure regulators shall be installed on the irrigation system to ensure the dynamic pressure of the system is within the manufacturers recommended pressure range.
 - iv. Manual shut-off valves (such as a gate valve, ball valve, or butterfly valve) shall be installed as close as possible to the point of connection of the water supply.
 - v. Master valve and flow sensing device for non-residential projects.
 - vi. All irrigation emission devices must meet the requirements set in the ANSI standard, ASABE/ICC 802-2014. "Landscape Irrigation Sprinkler and Emitter Standard," All sprinkler heads installed in the landscape must document a distribution uniformity low quarter of 0.65 or higher using the protocol defined in ASABE/ICC 802-2014.
 - vii. Areas less than ten (10) feet in width in any direction shall be irrigated with subsurface irrigation or other means that produces no runoff or overspray.
- f. For non-residential projects with landscape areas of 1,000 sq. ft. or more, a private submeter(s) to measure landscape water use shall be installed.
3. At the time of final inspection, the permit applicant must provide the Landscape Planning Division with a certificate of compliance, Irrigation Audit report and controller programming, irrigation schedule and a schedule of landscape and irrigation maintenance.

Tree Protection Notes

City of Ontario

Tree Protection During Construction Notes

1. Existing trees shall be identified and preserved with protective fencing to form a Tree Protection Zone (TPZ). This area encircles the tree at the outer most edge of the root zone and protects the roots growing typically within the top 18"-24" of the soil. The TPZ is defined by its "critical root radius." It is more accurate than the dripline for determining the TPZ of trees. To calculate critical root radius, measure the tree's diameter (dbh) 4.5 feet above the ground. Measure in inches. For each inch, allow for 1 to 1.5 feet of radius. If a tree's dbh is ten inches, its critical root radius is 10 to 15 feet.
2. Protective fencing shall be installed prior to any earthwork and until work is complete. Fencing shall be three feet to four feet in height and installed at the outer most edge of the Tree Protection Zone (TPZ). The temporary fencing shall be chain link fencing or other approved durable material. Post "Tree Protection Zone – Keep Out" signs on the TPZ fencing.
3. No construction or staging equipment is allowed within the Tree Protection Zone including heavy equipment that will compact and damage the roots.
4. No disposal of construction materials or by products including paint, plaster or chemical solutions is allowed within the Tree Protection Zone.
5. Natural or preconstruction grade shall be maintained within the Tree Protection Zone. At no time shall soil be in contact with the tree trunk above the root flare.
6. The Tree Protection Zone should be irrigated sufficiently with clean potable water to keep the tree in good health and vigor before during and after construction. Deep watering may be necessary on a weekly basis. Verify depth of irrigation to roots.
7. Apply a 4"-6" layer of mulch in the TPZ, 1 foot away from the trunk, before construction begins.
8. Any work required to be conducted in the ground within the Protection Zone shall be accomplished with hand tools or an air spade.
9. Pruning for clearance, if needed, shall be done to prevent damaging branches with large equipment. All pruning shall be in accordance with industry standards, (International Society of Arboriculture or ANSI A300), under the direction of a Certified Arborist.
10. Avoid cutting roots larger than 2" diameter. Cuts should be clean and made at right angles to the roots. When practical, cut roots back to a branching lateral root. Trenches for piping shall be bored under at a minimum of 36" deep. Consult a Certified Arborist to be present if more than 33% of the root zone is impacted or roots greater than 2" within 5' of the trunk will be cut, to ensure tree stability and health.
11. Protect soil and roots from compaction in landscape areas used for driveways, storage or parking with a layer of geotextile fabric and 6" of crushed gravel.



**LANDSCAPE
ARCHITECT**

**CITY OF ONTARIO
Landscape Planning Division**

**Certificate of
Compliance**

Senior Landscape Planner 909/395-2237

Associate Landscape Planner 909/395-2615

Project Name/Address _____

Plan check # B _____

The undersigned Landscape Architect certifies that the complete landscape and irrigation installation is in compliance to approved plans. Any deviation to approved plans shall require a re-submittal to the Landscape Planning Division for review and approval prior to installation.

LANDSCAPE ARCHITECT'S INSPECTION	DATE / INITIAL
1. Hardscape construction complies with approved plan	_____/____
2. Irrigation installation verified: trench, pipe size, pressure test, coverage test	_____/____
3. Irrigation controller chart with landscape maintenance schedule	_____/____
4. Soil report, compaction test and amendments verified with receipt	_____/____
5. Verification of plant material, quantity, and quality	_____/____
6. Irrigation audit verified including controller and programming set up	_____/____
7. Water Budget: Landscape SF _____ MAWA: _____ Gal/yr ETWU = _____ Gal/yr	

After the receipt of this Certification, the Landscape Planner will conduct the final landscape Inspection. The Owner's Representative and Landscape Contractor shall be present.

Landscape Architect (Print)

Company Name

Landscape Architect (Signature)

Address

License Number

Phone Number